



# CITY OF BISHOP

377 West Line Street - Bishop, California 93514  
Post Office Box 1236 - Bishop, California 93515  
760-873-8458 publicworks@ca-bishop.us  
www.ca-bishop.us

## **PUBLIC WORKS REPORT**

September 2008

### **WATER**

1. Assisted Wood Rodgers in efficiency testing of Wells 2 and 4. Still awaiting results of those tests.
2. Made minor adjustments and repairs to the Sodium Hypochlorite Generator at Well 4.
3. Removed weeds and debris from Tank Site.
4. Took monthly readings of all water meters.
5. Took routine Bacteria Samples.
6. Potholed water mains in various locations under West Pine and Grove Streets for future water main replacement projects.
7. Serviced electric motors at all three wells.
8. Removed and replaced fill stem at the Fowler Street Materials Pit to allow for trucks to fill off of street.
9. Began potholing all water services on South Second Street in anticipation of the rehabilitation project on that street.

### **SEWER**

1. Continued TV inspections of all sewer mains under streets that have rehabilitation projects scheduled.
2. Through TV inspections we found three (3) more collapsed sewer mains. These repairs were made the following week.

The locations are as follows:

400 Block of Short Street

Two of them under the 600 block of Grove Street

Intersection of Clarke and South Second Streets

3. Serviced all electric motors at the Waste Water Treatment Plant.
4. Made routine inspections of Grease interceptors.
5. With the video camera we started the process of pinning down exactly where our grease problem on East Pine is coming from.
6. Generated a No Spill Certification for the State and reported the same.
7. Performed routine Main Line cleaning in trouble areas.
8. Continued removing trees as time permits along fence line inside of the Waste Water Treatment Plant.
9. Disced the Eastern Sierra Community Service District's ponds in trade for them holding water for us this coming spring.
10. Cleaned Grit and Sludge drying beds.
11. Constructed new sewer lateral at customers request at 325 Clarke Street.
12. Ran the Wye Road diversion to the City for three (3) weeks.

## **STREETS**

1. Repaired and or replaced wheel stops in City parking lots.
2. Added fill to low shoulders on East Line Street.
3. Cleaned trash from fence line on north side of Wye Road.
4. Provided weed control on city streets and alleys.
5. Repaired and or replaced various Street Signs.
6. Continued with the process of developing Storm Drain information on GIS.
7. Swept city streets and alleys.
8. Completed the process of inventorying of all the City's Street Signs and Traffic Markings.
9. Reviewed and commented on Plans and Specifications for the South Second Street Project.
10. Accompanied Eastern Sierra Engineering on field reviews of Grove Street for the Safe Route To Schools project.

**MISCELLANEOUS.**

1. Made repairs to hydraulic hoses on older Street Sweeper.
2. Removed wheel stops in the Police Department parking lot at the Chief's request..
3. Hauled off trash and debris from the Fowler Street trash pit.
4. Made minor repairs and performed maintenance to Light Trucks and Heavy Equipment.
5. Provided weekly Safety Meetings for Public Works Crew.