



CITY OF BISHOP

377 West Line Street - Bishop, California 93514
Post Office Box 1236 - Bishop, California 93515
760-873-8458 publicworks@ca-bishop.us
www.ca-bishop.us

Public Works Report

June 2010

Water

1. Removed and replaced a 12 inch mainline valve in the Vons driveway. Old valve would not operate.
2. Installed water meter at 466 South Main Street (Shell station and car wash).
3. Conducted radio path study with ECO:LOGIC for the SCADA project.
4. Made minor modifications to sodium hypochlorite generator.
5. Continued annual exercising of all main line valves.
6. Continued annual testing of back flow valves.
7. Performed grounds maintenance at Wells 2 and 4.
8. Took monthly readings of all water meters.
9. Took routine bacteria samples.
10. Met with new manager of Indian Creek Community Services District.
11. Advertised May, Willow, and North Third Water Improvements project for bids.

Sewer

1. Completed construction of the Keough and Hobson Streets sewer replacement project.
2. Granite construction was awarded bid to replace 15 inch sewer main under Hanby Avenue and replace all laterals.
3. State Water Resources Board conducted their yearly inspection of wastewater treatment plant.
4. Performed grounds maintenance at the wastewater treatment plant.
5. Made routine inspections of grease interceptors.
6. Generated a No Spill Certification for the state and reported the same.
7. Performed routine main line cleaning in trouble areas.

8. Placed soil spoils from the Grove Street Project in low areas of the 40 acre pasture.
9. Met with potential consultant/contractor for Headworks project.

Streets

1. Granite Construction resumed work on the Hanby Avenue Pavement Reconstruction Project.
2. Provided weed control on city right of ways.
3. Swept city streets and alleys.
4. Patched potholes where needed.

Miscellaneous

1. Provided traffic control for the Bishop High School during graduation.
2. Provided weekly tail gate safety meetings.
3. Replaced two old computers in Public Works office that ran very slow and presented security risks.
4. Met with radio stations regarding cooperative announcements with Mammoth Lake Community Water District.
5. Participated in agency meeting regarding potential high runoff in Bishop Creek.
6. Participated in review of propane tank installations at city facilities.
7. Received final product from Environmental Constraints Assessment project.
8. Continued to work with Inyo Mono Advocates for Community Action in support of Silver Peak Apartments project.