



CITY OF BISHOP

377 West Line Street - Bishop, California 93514
Post Office Box 1236 - Bishop, California 93515
760-873-8458 publicworks@ca-bishop.us
www.ca-bishop.us

Public Works Report

February 2011

Water

1. Qualcon Contractors began work on Project A.
2. Repaired water leak on 4 inch cast iron main under Johnston Drive and constructed blow-off on same line.
3. Finalized plans and specifications for the North Second Street Water Line project.
4. Adjusted valve box at 475 North Third at owners request.
5. Eco:Logic continues to work with FCC to obtain radio licensing for SCADA project.
6. Located water services under North Third, East Elm, and Short Streets for Project A construction.
7. Performed grounds maintenance at Wells 2 and 4.
8. Took monthly readings of all water meters.
9. Took routine bacteria samples.
10. Interviewed consultants for Tank project, selected Resource Concepts Incorporated of Minden, and negotiated contract for first phase of work.
11. Participated in Integrated Regional Water Management Plan teleconference.

Sewer

1. Made repairs to failed sludge valve in south clarifier.
2. Began construction of an H-Flume at the 40 acre pasture to measure flow of discharged water.
3. Marked all sewer facilities under roads affected by Project A.
4. Replaced sewer lateral at 562 Grove Street.
5. Cleaned sludge and grit drying beds. Also replaced filter media in the sludge beds.

6. Continued to run the Wye Road Diversion on a full time basis. At this time we have not had a plugged sewer in the areas that were causing us problems when diversion was not ran on a continual basis.
7. Replaced Fire Eye in boiler control panel and ordered another for backup.
8. Performed grounds maintenance at the Waste Water Treatment Plant.
9. Made routine inspections of grease interceptors.
10. Performed maintenance on the Johnston Drive Lift Station.
11. Generated a No Spill Certification for the state and reported the same.
12. Performed routine main line cleaning in trouble areas.
13. Continued video effort to inventory all sewer facilities under city right of way.
14. Installed new compressor pump in the Johnston Drive Lift Station.
15. Prepared Spanish version of grease flier.

Streets

1. Construction of Project A began. As of the 28th February all tree removal has been completed.
2. Met with Verizon and Suddenlink staff concerning needed utility relocations on Project A.
3. Held public meeting concerning construction of Project A.
4. Repaired various trip hazards in sidewalks and alleys.
5. Patched potholes and gutters in city streets.
6. Filled separation between curb and sidewalk with grout on Spruce Street.
7. Attended Inyo Local Transportation Commission meeting.
8. Continued environmental work on Pine to Park Path.
9. Worked to resolve potential issue with draft easements for the Wye Road Intersection project.
10. Completed installation of new flag sleeves for American Legion Auxillary.

Miscellaneous

1. Provided weekly tail gate safety meetings.
2. Cleaned up and organized all Public Works facilities.

3. Hauled trash and debris from Fowler Pit to the Sunland Landfill.
4. Performed maintenance to light trucks and equipment.
5. Participated in Bishop Tree Committee meeting.
6. Met with representative of High Sierra Energy Foundation about energy efficiency and potential funding.
7. Participated in webinar concerning use of LiDAR data in GIS.
8. Participated in meeting of Working Group for update of the Bishop General Plan.
9. Selected HJW Geospatial for LiDAR project and negotiated contract for the work.