



CITY OF BISHOP

377 West Line Street - Bishop, California 93514
Post Office Box 1236 - Bishop, California 93515
760-873-8458 publicworks@ca-bishop.us
www.ca-bishop.us

Public Works Report

July 2011

Water

1. Conspec started and completed the Iris Street Water Improvements Project.
2. Rivers Edge Construction completed the North Second Street Water Improvements Project.
3. Resolved issue with hydrant constructed by North Second Street Water Improvements Project obstructing access to resident's gate.
4. Repaired leak on 3/4" copper service at 669 Maple Avenue.
5. Relocated sample tap at Well 4 at the direction of California Department of Public Health.
6. Initiated a bacteria sampling for Well 1. This will ensure well is ready to use in the event of an emergency.
7. Resource Concepts Incorporated completed study for new water storage tank design and submitted their findings.
8. Continued main line valve exercising.
9. Replaced failed mainline valve at the intersection of Willow Street and Moffett Drive
10. Stantec radios at wells, tank site and shop. Project should be completed by the by early August.
11. Performed grounds maintenance at Wells 2 and 4.
12. Took monthly readings of all water meters.
13. Took routine bacteria samples.
14. Investigated video inspection services for main supply line between Well 4 and town.

Sewer

1. City forces installed conduit from last manhole on Johnston Drive to lift station to accommodate SCADA equipment.
2. Marked all sewer facilities under roads affected by the Iris Street Water Improvements Project.

3. Began the process to upgrade air compressors at the lift station.
4. Cleaned sludge and grit drying beds.
5. Performed grounds maintenance at the Waste Water Treatment Plant.
6. Made routine inspections of grease interceptors.
7. Performed maintenance on the Johnston Drive Lift Station.
8. Generated a No Spill Certification for the State and reported the same.
9. Performed routine main line cleaning in trouble areas.
10. Continued video effort to inventory all sewer facilities under city right of way.
11. Continued very slow work with consultant on Headworks project.
12. Worked on equipment purchase necessary to upgrade Johnston Drive Lift Station.

Streets

1. Exposed and repaired sinkhole on North Warren Street in front of Inyo Mono Body Shop.
2. Relocated mail box on South Main Street.
3. Built an asphalt ramp at 486 Hanby to provide a smoother transition from street to driveway.
4. While exercising main line water valves crew would perform weed removal in gutter around valves.
5. Swept city streets and alleys.
6. Went door to door on Short Street affected by Road Improvement Project A to get feedback on project and related communication.
7. Briefed Inyo Board of Supervisors on Mobility Element update.
8. Held joint workshop between the City Council and the Planning Commission on the Mobility Element update.
9. Briefed Bishop Paiute Tribe members on the Mobility Element update.
10. Worked with Triad on plans for Wye Road Storm Drain project.
11. Evaluated citizen suggestion to lower speed limit on East Line Street near Bishop Creek Canal.
12. Reviewed environmental document for Pine to Park Path.

Miscellaneous

1. Organized help from Inyo County Probation to plant trees at 380 Short Street in the new greenbelt provided by Project A.
2. Swept airport runways to remove trash and debris left from the Fourth of July fireworks show.
3. Provided traffic control equipment to the Farmers Market.
4. Hauled trash and debris from Fowler Pit to the Sunland Landfill.
5. Performed maintenance to light trucks and equipment.
6. Met with the Federal Emergency Management Agency concerning Flood Insurance Rate Map update for Inyo County and related ordinance update for the city of Bishop.
7. Interviewed candidates for vacant Maintenance Worker position.
8. Worked with consultant on LiDAR project on final deliverables under the contract.