



CITY OF BISHOP

377 West Line Street - Bishop, California 93514
Post Office Box 1236 - Bishop, California 93515
760-873-8458 publicworks@ca-bishop.us
www.ca-bishop.us

Public Works Report

September 2011

Water

1. Replaced failed 3/4 inch water service at 505 West Elm Street.
2. Potholed various locations to verify water main sizes and material along South Warren Street in anticipation of the future street improvement project. This work will help determine which water mains need to be replaced with the project.
3. Aquatic Inspections cleaned, inspected and made minor repairs to the 1 million gallon storage tank.
4. Updated our Bacteria Sample Site Plan to include Triggered Source Monitoring.
5. Performed grounds maintenance at Wells 2 and 4 as well as the tank site.
6. Took monthly readings of all water meters.
7. Took routine bacteria samples.

Sewer

1. Installed new manhole on North main Street between Willow and Church Street.
2. Cleaned weeds and debris from ponds 5 and 6.
3. Cleaned plugged sewer at the intersection of West Elm and North Fowler Street.
4. Steam cleaned grease from cat walks and hand railings at the Waste Water Treatment Plant..
5. Started preliminary survey work on the 12 inch sewer main in the back of the park and the 8 inch main that serves the Holiday Inn Express. Survey work was done in preparation for replacement of approximately 960 feet of sewer main.
6. Partially in support of work at the Eastern Sierra Community Service District plant that brought up a potential issue related to low alkalinity in source water, sampled and tested city wells for inorganic chemicals and general minerals. City water was considered to be representative of the District's source water.
7. SCADA work continues.
8. Cleaned sludge and grit drying beds.

9. Performed grounds maintenance at the Waste Water Treatment Plant.
10. Made routine inspections of grease interceptors.
11. Generated a No Spill Certification for the State and reported the same.
12. Performed routine main line cleaning in trouble areas.
13. Continued very slow work with consultant on Headworks project.

Streets

1. Cleaned trash and debris from all drop inlets in preparation for winter storms.
2. Assisted the Community Services Department with determining placement of no parking signs and zones along Spruce Street and Yaney Street.
3. Patched potholes that presented possible safety issues.
4. Swept city streets and alleys.

Miscellaneous

1. Assisted the Tri County Fairgrounds in preparation of the Fall colors Car Show by sweeping parking lot.
2. Provided traffic control equipment to the farmers market.
3. Hauled trash and debris from Fowler Pit to the Sunland Landfill.
4. Performed maintenance to light trucks and equipment.