

# **PUBLIC WORKS REPORT**

## **July 2006**

### **WATER**

1. Removed 4 older model main line valves on Home Street and replaced them with lower profile modern valves. This work was done to accommodate the Home Street Improvement Project.
2. Raised 3 hydrants on Home Street to assure they were above finish grade of new sidewalks.
3. Tested backflow valves within the City.
4. Took routine readings of water meters.
5. Continued working with Layne Christensen on the Well 1 rehabilitation project.

### **SEWER**

1. Cleaned and videoed nearly 20,000 feet of sewer main line. This is done as part of Water and Sewer Master Plan.
2. Performed annual service of aerators on the sewer ponds.
3. Repaired broken sewer main in the intersection of West Pine and Fowler Streets.
4. Removed south sludge pump and sent it off for repairs.
5. Cleaned plugged sewer at the 600 block of West Elm Street.
6. Removed and cleaned grit pump.
7. Cleaned sludge and grit drying beds.
8. Made routine inspection of grease interceptors.

## **STREETS**

1. Began the Home Street Improvement Project on July 18, 2006.
2. Performed inspections for the Home Street Project.
3. Ground and patched sidewalk deviations at the northeast corner of West Pine and Fowler Streets.
4. Made minor changes to alley off of Willow Street directly across from Moffett Street. This work was done to enhance drainage in the alley.
5. Continued with annual traffic painting.
6. Swept all City streets and alleys.

## **MISCELLANEOUS**

1. Performed application screening, interview process and hired a new Maintenance Worker 2.
2. Hauled trash and debris from the Fowler Street Pit to the Sunland Landfill.
3. Performed routine maintenance and made minor repairs to light trucks and heavy equipment.
4. Cleaned weeds and debris from shop planters.