

# **PUBLIC WORKS REPORT**

## **August 2006**

### **WATER**

1. Kendall Engineering started and completed the Well 2 Main Line Loop project.
2. City of Bishop crew installed a 14" tee and valve cluster at Well 2.
3. Replaced various main line valves on Home Street.
4. Raised three fire hydrants on Home Street to meet new sidewalk grades.
5. Continued with water main line map for the GIS project.
6. Installed a new Mueller fire hydrant at the intersection of North Warren and Grove Streets.
7. Made minor repairs and serviced the sodium hypochlorite generator at Well 4.
8. Began annual main line valve exercising.
9. Took routine water samples.
10. Took monthly readings of water meters.

### **SEWER**

1. Removed failing manhole at Home and Grove Streets and replaced it with a modern manhole.
2. Repaired a sewer lateral at 336 South Second Street.
3. Made routine inspections of grease interceptors.
4. Performed routine maintenance on the grit pump.
5. Cleaned plugged sewer at the 200 block of May Street.
6. Cleaned grit and sludge drying beds.

## **STREETS**

1. Continued with the construction of the Home Street Improvements.
2. Assisted home owner at 212 May Street with removal and placement of new sidewalk as part of the Sidewalk Safety Program.
3. Provided weed control on City streets and alleys; paying close attention to puncture vine.
4. Swept all City streets and alleys.
5. Repaired and replaced various street signs.
6. Patched potholes and gutters on City streets.

## **MISCELLANEOUS**

1. Swept Fairgrounds prior to opening of Tri-County Fair.
2. Performed routine maintenance and made minor repairs to light trucks and heavy equipment.