



CITY OF BISHOP

377 West Line Street - Bishop, California 93514
Post Office Box 1236 - Bishop, California 93515
760-873-8458 publicworks@ca-bishop.us
www.ca-bishop.us/CityofBishopPublicWorks.htm

PUBLIC WORKS REPORT JANUARY 2007

WATER

1. Repaired water leaks at the following locations:

6" Cast Iron main under South Second Street

4" Cast Iron main under Johnston Drive.

2" Galvanized main under North Second Street.

2. Replaced failed 5/8" Copper water service at 482 Clarke Street.

3. Installed a new 3/4" water service at 636 Keough Street.

4. Met with Representative from SCADA Technologies to diagnose deficiencies and problems with the current Telemetry and Alarm systems.

5. Removed 17 large Arizona Cypress trees along the South side of the Intake at Well 4.

The wood from the trees was donated to IMACA.

6. Performed grounds maintenance at Well 2.

7. Took routine water samples from Wells and Distribution System.

8. Took monthly readings of all water meters.

9. Advertised and opened bids for a Portable Back up Generator to serve Wells 2 and 4.

This generator will also have the ability to serve the Waste Water Treatment Plant.

10. Continued with the Water Master Plan efforts.



CITY OF BISHOP

377 West Line Street - Bishop, California 93514

Post Office Box 1236 - Bishop, California 93515

760-873-8458 publicworks@ca-bishop.us

www.ca-bishop.us/CityofBishopPublicWorks.htm

SEWER

1. Cleaned plugged sewers at the following locations:

The intersection of Willow and Moffett Streets.

The 600 block of West Elm Street.

2. Inspected the construction of new sewer laterals at the Hospital and The Willow Street Plaza Project.
3. Performed annual maintenance to the Boiler at the Waste Water Treatment Plant.
4. Replaced a failed Electric Motor at the Johnston Drive Lift Station.
5. Installed a new Flow Recorder at the Head Works of the Waste Water Treatment Plant.
6. Evaluated 36 manholes for Nolte as part of the ongoing Sewer Master Plan.
7. Made routine inspections of Grease Interceptors. While these inspections were performed Dave Mappus handed out educational literature to owners of the interceptors.
8. Irrigated the 40 acre Pasture south of the Sewer Ponds.

STREETS

1. Swept all City streets and alleys.
2. Began annual Crack Sealing Operations.
3. Replaced damaged Wheel Stop in the City Parking Lot behind BBQ Bills.
4. Patched Potholes on various streets.



CITY OF BISHOP

377 West Line Street - Bishop, California 93514

Post Office Box 1236 - Bishop, California 93515

760-873-8458 publicworks@ca-bishop.us

www.ca-bishop.us/CityofBishopPublicWorks.htm

5. Removed five trees at the east end of Yaney Street. The trees were leaning into the Street and becoming a safety issue.
6. Boyd Fence installed a safety rail in front of the Trophy Shop on Home Street.
7. Repaired and or replaced various Street Signs.
8. Evaluated all City Streets to prioritize a list of future Street Improvements for funding.
9. Spread cinders on various city streets after snow storm.

MISCELLANEOUS

1. Made minor repairs and performed maintenance to Heavy Equipment and Trucks.
2. Continued with the GIS efforts.
3. Cleaned trash and debris from Shop planters.
4. Attended monthly Local Transportation Meeting.