



# CITY OF BISHOP

377 West Line Street - Bishop, California 93514  
Post Office Box 1236 - Bishop, California 93515  
760-873-8458 publicworks@ca-bishop.us  
www.ca-bishop.us

## **PUBLIC WORKS REPORT**

January 2008

### **WATER**

1. Repaired water leak on 5/8" copper water service at the intersection on South Third and Clarke Streets.
2. Installed Valve Boxes at the following locations:
  - 137 East South Street
  - 175 East South Street
  - 359 East South Street
3. Removed and replaced failed 2" Main Line Gate Valve on Church Street.
4. Removed and replaced failed Curb Stop valve at 359 South Street.
5. Tested and ran 300 KW Generator at Well 2.
6. Performed a test that proved that Well 2 can fill the 1 Million Gallon Storage Tank. There were no adverse effects that resulted from this test.
7. Burned brush and debris at Well 4 and did overall sight cleanup.
8. Built storage racks for Generator equipment at Well 2.
9. Started the process of a Backflow Survey of all Commercial accounts. While doing this survey Staff is verifying that what we are billing these customers is correct.
10. Took monthly readings of all water meters.
11. Took routine Bacteria Samples.

### **SEWER**

1. No plugged sewers to report this month.
2. Burned brush and limb piles at the Waste Water Treatment Facility.

3. Irrigated the 40 acre Pasture south of the Sewer Ponds.
4. Made routine inspections of Grease interceptors.
5. Generated a No Spill Certification for the State and reported the same.
6. Performed routine Main Line cleaning in trouble areas.
7. Cleaned Grit Drying beds.
8. City Council gave approval for the joint purchase of a Sewer Camera with the Eastern Sierra Community Service District
9. Exposed sewer main on Clarke Street for future Manhole construction.

## **STREETS**

1. Performed Snow Removal operations on City streets.
2. Spread cinders on icy intersections around the schools and various locations throughout the city.
3. Repaired and or replaced various Street Signs.
4. Patched Potholes and gutters where needed.
5. Swept city streets and alleys.
6. Innovative Concrete completed the replacement of failed sidewalks on Mac Iver Street.
7. Removed downed tree on West Elm Street that fell during high winds
8. Exposed and repaired the Corrugated Metal Storm Drain Pipe under South Warren Street at the intersection of Lagoon
9. Cleared blocked Storm Drains with Vacoon Truck during heavy rains
10. Assisted the Department of Water and Power with repairs to a damaged culvert under South Fowler Street
11. Repaired washed out shoulders on streets that do not have curbs
12. Completed an inventory of all Storm Drains in the City of Bishop.

## **MISCELLANEOUS.**

1. Applied De-icing material on all Cross Walks around the Bishop Schools at the request of the Police Chief.

2. Cleaned trash and debris from Shop planters.
3. Hauled off trash and debris from the Fowler Street trash pit.
4. Made minor repairs and performed maintenance to Light Trucks and Heavy Equipment.