



CITY OF BISHOP

377 West Line Street - Bishop, California 93514
Post Office Box 1236 - Bishop, California 93515
760-873-8458 publicworks@ca-bishop.us
www.ca-bishop.us

Addendum 1

12 August 2013

Wye Road Intersection Improvements Project

This addendum makes the following changes to the 22 July 2013 Bidding Information and Contract Documents for this project:

1. Replace Scope of Work, Section 7, in General Provisions, with the following: "The scope of the work shall consist of the work described in the contract documents for the Wye Road Intersection Improvements Project and as provided in the improvement plans."
2. Add the following: "On 12 August 2013 city forces measured groundwater about 35 feet north of the centerline of Wye Road at the location of the Stormwater Separator to be about 9 feet below the ground surface. The excavation was by backhoe and groundwater surface was observed for a period of about 10 minutes. The ground surface at the excavation is estimated to be 1 to 2 feet lower than the pavement at the Stormwater Separator."

David Grah
Director of Public Works