



CITY OF BISHOP

377 West Line Street - Bishop, California 93514
Post Office Box 1236 - Bishop, California 93515
760-873-8458 publicworks@ca-bishop.us
www.ca-bishop.us

Addendum 2

1 April 2014

Pine to Park Path Project

This addendum makes the following changes to the 11 March 2014 Bidding Information and Contract Documents for this project:

1. Section 13, Time of Completion, of the General Provisions: The contractor shall have 35 working days to complete the work.
2. Bid Item 6: Curb may be poured separately from sidewalk if curb and sidewalk are dowelled together with number 4 bars at 30 inch centers embedded at least 4 inches into concrete of curb and sidewalk. Dowell embedment shall either be by casting dowel into concrete or by epoxying dowel into drilled hole as approved by engineer.

David Grah
Director of Public Works