



CITY OF BISHOP

377 West Line Street - Bishop, California 93514
Post Office Box 1236 - Bishop, California 93515
760-873-8458 publicworks@ca-bishop.us
www.ca-bishop.us

Addendum 1

26 August 2014

Warren, South, and Academy Streets Utility Improvement Project

This addendum changes the 2 August 2014 Bidding Information and Contract Documents for this project. Replace item 3, PVC Water Pipe and Pipe Casing, of section C, Materials with the following:

Fittings and valves shall conform to the provisions of the Bishop Specifications. Water line shall be polyvinyl chloride (PVC), cast iron outside diameter, distribution pipe, DR14 pressure class 305 with integral bell and spigot joints and conform to the following standards.

Product Standard:	ANSI/AWWA C900
Pipe Compound:	ASTM D1784 Cells Class 12454
Gasket:	ASTM F477
Integral Bell Joint:	ASTM D3139
Certifications:	ANSI/NSF Standard 61
Pipe Length:	20 feet laying length
Fire:	UL Standard 1285
Installation:	AWWA C605

David Grah
Director of Public Works