



CITY OF BISHOP

377 West Line Street - Bishop, California 93514
Post Office Box 1236 - Bishop, California 93515
760-873-8458 publicworks@ca-bishop.us
www.ca-bishop.us

Public Works Report

April 2015

Water

1. Repaired water leaks on water services at 606 N Main Street and 236 W Pine Street.
2. Layne Company began work on replacing the pump at Well 2.
3. Adjusted various curb stop valves within the limits of the Warren Street Improvement Project to accommodate new sidewalk and driveway grades.
4. Continued annual testing of all back flow valves within the city.
5. Continued annual main line valve exercising.
6. Continue working with Terra Verde to implement solar power at Wells 2 and 4.
7. Performed grounds maintenance at Wells 2 and 4 as well as the tank site.
8. Took monthly readings of all water meters.
9. Took routine bacteria samples.

Sewer

1. Constructed a new head gate to control flows between ponds 4 and 5.
2. Provided daily monitoring and made minor modifications to the Pilot Project.
3. Adjusted various sewer cleanouts within the limits of the Warren Street Improvement Project to accommodate new sidewalk and driveway grades.
4. Performed grounds maintenance at the Waste Water Treatment Plant.
5. Continued with the Collaboration effort with Eastern Sierra Community Services District.
6. Cleaned sludge drying beds.
7. Made routine inspections of grease interceptors.
8. Performed routine main line cleaning in trouble areas.

Streets

1. V&C Construction continued work on the Warren Street Improvement Project. At this time they are approximately two thirds of the way finished.
2. Began installing miscellaneous street signs along the Warren Street Project.
3. Installed a new drop inlet on 100 block of West Pine Street and 90 feet of pipe.
4. Patched potholes in City streets that posed potential safety issues.
5. Repaired and or replaced damaged street signs.
6. Participated in Inyo Local Transportation Commission meeting.

Miscellaneous

1. Fabricated and installed flower pot hangers on the Main Street planters.
2. Constructed approximately 100 feet of Valley Gutter in the Sunrise Mobile Home Park.
3. Public Works Crew attended Trench Safety and Confined Space training.
4. Installed flag sleeves in the sidewalk at various locations. This work was done to assist the American Legion.
5. Performed maintenance and serviced Public Works vehicles
6. Provided weekly tail gate safety for the Public Works crew.
7. Hauled trash and debris from Fowler Pit to the Sunland Landfill.