



# CITY OF BISHOP

377 West Line Street - Bishop, California 93514  
Post Office Box 1236 - Bishop, California 93515  
760-873-8458 publicworks@cityofbishop.com  
www.cityofbishop.com

## Addendum 2

**21 December 2015**

### **Parks Restrooms Project**

This addendum changes the 3 December 2015 Bidding Information and Contract Documents for this project to make the electrical panel and wiring requirements the same for both buildings.

Replace CITY PARK PANEL/WIRING on page 35 of Special Provisions with the following:

CITY PARK PANEL/WIRING: One 100 amp, 120/240v, single phase, 3-wire, commercial grade Combination Service Entrance Panel, 16 space, 24 circuits with 100 amp main circuit breaker, shall be mounted in the utility chase in the restroom building. All breakers shall be snap-on type, minimum 10,000 A.I.C. RMS (Sym). Cable shall be appropriate gage for current and in EMT piping with compression fittings.

David Grah  
Director of Public Works