



CITY OF BISHOP

377 West Line Street - Bishop, California 93514
Post Office Box 1236 - Bishop, California 93515
760-873-8458 publicworks@ca-bishop.us
www.ca-bishop.us

Addendum 1

29 April 2011

Church Street Water Improvements Project

This addendum makes the following changes to the 25 April 2011 Bidding Information and Contract Documents for this project:

1. Page 30 of 33 of the Special Provisions, **19. Traffic Control, Flagging** section: Add the sentence "The Contractor shall provide flaggers whenever a lane is closed."
2. Page 30 of 33 of the Special Provisions, **19. Traffic Control, Phasing and Access Requirements** section: Replace the first sentence with "At all times a minimum of 1 smooth and firm lane at least 11 feet wide shall be open on all streets included in construction."

David Grah
Director of Public Works