



CITY OF BISHOP

377 West Line Street - Bishop, California 93514
Post Office Box 1236 - Bishop, California 93515
760-873-8458 publicworks@ca-bishop.us
www.ca-bishop.us

Public Works Report

February 2015

Water

1. Adjusted 8 inch water main under West Line Street to accommodate new 18 inch Storm Drain.
2. Replaced failing 4 inch waste valve at Well 1. Valve was leaking and couldn't be repaired.
3. Removed a buried 4 inch valve on the Church Street main.
4. Continue working with Terra Verde to implement solar power at Wells 2 and 4 (as well as wastewater treatment plant).
5. Performed grounds maintenance at Wells 2 and 4 as well as the tank site.
6. Took monthly readings of all water meters.
7. Took routine bacteria samples.
8. Attended presentation regarding new groundwater regulations at the Inyo Board of Supervisors meeting.

Sewer

1. Provided daily monitoring of the Pilot Project.
2. Lowered the Wash Tub's sewer lateral to accommodate the new 18" storm drain.
3. Made alterations to an existing repair on the sewer trunk line in the canal.
4. Burned tules on Pond 3 and weeds around all ponds.
5. Grit dewatering channel experienced a major failure. Frost company mobilized in and made repairs.
6. Videoed and evaluated sewer main lines that have not been reviewed in some time.
7. Performed routine maintenance to the Johnston Drive Lift Station.
8. Performed grounds maintenance at the Waste Water Treatment Plant.
9. Continued with the Collaboration effort with Eastern Sierra Community Services District.

10. Cleaned sludge drying beds.
11. Made routine inspections of grease interceptors.
12. Performed routine main line cleaning in trouble areas.
13. Met with staff from Lahontan Regional Water Quality Control Board concerning planned update to waste discharge requirements for the wastewater treatment plant.

Streets

1. Continued construction of the Warren Street Improvements project.
2. Removed all stop signs within the limits of the Warren Street Improvements project and placed them on barricades.
3. Patched potholes in City streets that posed potential safety issues.
4. Repaired and or replaced damaged street signs.
5. Participated in Inyo Local Transportation Commission meeting.
6. Participated in Active Transportation Program teleconference.
7. Participated in Warren Street Focus Group meeting.
8. Worked with Bishop Library to resolve access issues related to the Warren Street project.

Miscellaneous

1. Continued the process of removing trip hazards and failed pavement on the path within the City Park. Path is being replaced with concrete in these sections.
2. Installed water connections into 2 locations at the Inyo County Library for a future landscape project.
3. Performed maintenance and serviced Public Works vehicles
4. Provided weekly tail gate safety for the Public Works crew.
5. Hauled trash and debris from Fowler Pit to the Sunland Landfill.
6. Met with Mammoth Brewery concerning their continuing plan to construct a facility in the Bishop area.