

Important Information About Your Drinking Water

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

Monitoring Requirements Not Met for the City of Bishop during November 2018

The City of Bishop failed to monitor as required for state drinking water standards in November 2018 and, therefore, was in violation of the regulations. Even though this failure was not an emergency, customers have a right to know what they should do, what happened, and what the city did to correct the situation.

The city is required to monitor your drinking water for specific contaminants every month. Results of the regular monitoring are an indicator of whether or not the drinking water meets health standards. During November 2018, we did not meet every state monitoring requirement for bacteria. More information follows:

Contaminant:	Coliform Bacteria
Required number of samples:	5
Number of Samples Taken:	4

What should I do? There is nothing you need to do at this time.

What happened and what was done to correct? Four routine samples were taken in November 2018 when 5 should have been taken. The City has updated its Bacterial Monitoring Plan to insure this error will not happen in the future.

For more information, please contact the City of Bishop Public Works Department at (760)873-8458 or at 377 West Line Street.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

This notice is provided to you by the City of Bishop.