



CITY OF BISHOP

377 West Line Street - Bishop, California 93514
Post Office Box 1236 - Bishop, California 93515
760-873-8458 publicworks@cityofbishop.com
www.cityofbishop.com

Addendum 1

14 December 2015

Parks Restrooms Project

This addendum changes the 3 December 2015 Bidding Information and Contract Documents for this project.

Increase depth of conduit for electrical service at City Park location to 30 inches, add hand hole, and make other changes shown to electrical conduit for electrical service shown on attached sheet.

David Grah
Director of Public Works

