



CITY OF BISHOP

377 West Line Street - Bishop, California 93514

Post Office Box 1236 - Bishop, California 93515

760-873-8458 publicworks@cityofbishop.com

www.cityofbishop.com

Addendum 1

July 31, 2020

Spruce, Yaney, Hanby Sidewalks Project

This addendum changes the July 28, 2020 Bidding Information and Contract Documents for this project.

There is a conflict between the General Provisions, section B. Bid Items Item 6, Irrigation and the plans on page C15. The detail on C15, Irrigation Service Detail should read 1, ½" Wilkens 350 XL backflow device. All irrigation pipe shall be 1, ½".

Deston Dishion
Director of Public Works