



CITY OF BISHOP

377 West Line Street - Bishop, California 93514
Post Office Box 1236 - Bishop, California 93515
760-873-8458 publicworks@cityofbishop.com
www.cityofbishop.com

Addendum 2

10 September 2019

West Jay Street Extension

This addendum changes the 17 August 2019 Bidding Information and Contract Documents for this project:

On page 31 of 31 change the first sentence of PVC Water Line to "Water line shall be polyvinyl chloride (PVC) water distribution pipe conforming to American Water Works Association (AWWA) C900 DR14 requirements with integral bell and spigot joints, shall meet the requirements of ANSI/NSF 61 "Drinking Water System Components - Health Effects", and shall be manufactured to cast iron outside diameters (CIOD) in accordance with AWWA C900."

A handwritten signature in blue ink, appearing to read "David Grah".

David Grah
Public Works